

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-0067:193

Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Siemens Building Technologies Inc., \*Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

<b>DESIGN:</b>	<b><u>Type</u></b>	<b><u>Model</u></b>
	Speaker/Strobe	SH25-S15-FW, -S17-FW, -S75-FW, -S110-FW SH25-S15-SW, -S17-SW, -S75-SW, -S110-SW SH70-S15-FW, -S17-FW, -S75-FW, -S110-FW SH70-S15-SW, -S17-SW, -S75-SW, -S110-SW SH25-S15S-FW, -S17S-FW, -S75S-FW SH25-S15S-SW, -S17S-SW, -S75S-SW SH70-S15S-FW, -S17S-FW, -S75S-FW SH70-S15S-SW, -S17S-SW, -S75S-SW SH25-S15S-S, -S17S-S, -S75S-S SH25-S15S-F, -S17S-F, -S75S-F SH-25-S15S-C, -S17S-C SH-70-S15S-C, -S17S-C SH70-S15S-F, -S17S-F, -S75S-F SH70-S15S-S, -S17S-S, -S75S-S

**RATING:** Speaker: 25 Vrms and 70 Vrms  
Strobes: -S15 (15 cd), 60 flashes/min  
-S17 (15/75 cd), 60 flashes/min  
-S75 (75 cd), 60 flashes/min  
-S110 (110 cd), 60 flashes/min

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction. Models with suffix -S17 and -S110 are for suitable for ceiling/wall mount. All other Models are for wall mount only.

**MARKING:** Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

**APPROVAL:** Listed as speaker/strobes for use with separately listed compatible fire alarm control units. For indoor use only. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** 7320-0065:117

\*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**